



Ref. Certif. No

NO129165

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

LED Power Supply

Name and address of the applicant

Foshan Eaglerise Power Science & Technology (Shunde) Co., Ltd.
No.4, East Huanzhen Road, Beijiao Shunde, Foshan, Guangdong
China

Name and address of the manufacturer

Foshan Eaglerise Power Science & Technology (Shunde) Co., Ltd.
No.4, East Huanzhen Road, Beijiao Shunde, Foshan, Guangdong
China

Name and address of the factory

See next page(s)

Note: When more than one factory, please report on page 2

☒ Additional Information on Page 2

Ratings and Principal characteristics

PRI: max. 1.5 A, 220-240 V~, 50/60 Hz
Centralized emergency power supply: 220-240 Vdc
SEC: max. 250 W, max. 10.41 A, 24 Vd.c. (under load), EOFv: 15%. Class II

Trademark /Brand (If any)



Customer's Testing Facility (CTF) Stage used

Model/Type Ref

LS-250-24 DALI-2 LI

Additional information (If necessary may also be reported on Page 2)

Independent type, SELV, constant voltage output, thermal protected 110 °C, ta: 45 °C, tc: 85 °C.

☐ Additional Information on Page 2

A sample of the product was tested and found to be in conformity with

IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017
IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016

As shown in the Test Report Ref. No. which forms part of this Certificate

REP022387

This CB Test Certificate is issued by the National Certification Body

Philip Pedersen vei 11,
NO-1366 Lysaker, Norway

Date: 19-01-2024

Sweet Yuan

Signature: Sweet Yuan
Certification department



Ref. Certif. No

NO129165

Foshan Eaglerise Power Science & Technology (Shunde) Co., Ltd.
No.4, East Huanzhen Road, Beijiao Shunde, Foshan, Guangdong
China

EAGLERISE ELECTRIC & ELECTRONIC (JI AN) CO., LTD
West Zone, Ji An County Industrial Park, Ji an County
Jiangxi Province
China

Additional Information (if necessary)



Philip Pedersen vei 11,
NO-1366 Lysaker, Norway

Date: 19-01-2024

Signature: Sweet Yuan
Certification department