

# ATTESTATION OF CONFORMITY

Issued to: Foshan Eaglerise Power Science & Technology (Shunde) Co., Ltd.  
No.4, East Huanzhen Road, Beijiao, Shunde, 528000 Foshan, Guangdong, China

For the product: LED power supply

Trade name:  EAGLERISE

Type/Model: LS-50-500 LI EXC, LS-50-600 LI EXC, LS-50-1100 LI EXC,  
LS-50-1150 LI EXC, LS-50-1200 LI EXC, LS-50-1250 LI EXC

Ratings: SELV, independent, Class II, IP20, constant current output, non-inherently short circuit proof;  
Other information refers to Attachment 7 of test report for details.

Manufactured by: Foshan Eaglerise Power Science & Technology (Shunde) Co., Ltd.  
No.4, East Huanzhen Road, Beijiao, Shunde, 528000 Foshan, Guangdong, China

Requirements: EN 61347-1:2015 + A1:2021  
EN 61347-2-13:2014 + A1:2017

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no 4917202.50.

This Attestation implies that the examined types are in accordance with the standards designated under the Low Voltage Directive (LVD) 2014/35/EU.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.

Arnhem, 8 May 2024

Number: 4917202.01AOC

DEKRA Testing and Certification (Shanghai) Ltd.,  
Guangzhou Branch



May Liu  
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

