

# Certificate of Conformity

Global-Mark Pty. Ltd., certify the electrical equipment described hereunder complies with standards listed herein and notifies the certificate holder to affix the authorised Approval Mark on the product of the same type and the Regulatory Compliance Mark (RCM) mark provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled. In placing the Approval and RCM mark on the product, the Responsible Supplier makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein. – This Certificate meets the requirements of a Recognised External Certification Scheme (EESS- RECS) and a Recognised External Approval Scheme (NSW-REAS).

## CERTIFICATION AND CERTIFICATE HOLDER DETAILS

Company Name	<b>Foshan Eaglerise Power Science &amp; Technology (Shunde) Co.,Ltd</b>	Other Name	
Address	<b>No 4 East Huanzhen Road, Beijiao Shunde, Foshan Guangdong 528000 China</b>		
Client ID	<b>107687</b>	Global-Mark File Number:	<b>107687-037</b>
Certificate Number & Approval Mark	<b>GMA-514667-EA</b>	Revision Number	<b>00</b>
Certification Standard(s)	<b>AS 61347.2.13:2018 &amp; AS/NZS 61347.1:2016 + A1 Lamp Control Gear - Part 2-13: Particular Requirements For D.C Or A.C Supplied Electronic Control Gear For Led Modules.</b>		
Type of Certification	<b>Electrical Safety Product</b>	Scheme	<b>Global-Mark Electrical Product Safety Certification Scheme</b>
			System 1 Approval

## CERTIFICATE DATES

Certificate Issue Date	<b>1/02/2023</b>
Certificate Last Update Date	
Certification Expiry Date	<b>1/02/2028</b>

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to [www.jas-anz.org/register](http://www.jas-anz.org/register) for verification.



**Certification Manager**




# Certificate of Conformity

CERTIFIED ELECTRICAL EQUIPMENT				
Declared Article	Product Description	Trade Name	Model Number	Rating
Power Supply or Charger	LED Power Supply	EAGLERISE	FLS-26-700 DALI-2 LD1	Input: LV supply: 220-240 Vac, 0/50/60 Hz, 0.2 A max., $\lambda$ : 0.45C-0.95 Centralized emergency power supply: 198-254 V= Output: 9-52Vdc, 60Vdc max, 150mA, 1.35-7.8W / 200mA, 1.8-10.4W / 250mA, 2.25-13W / 300mA, 2.7-15.6W / 350mA, 3.15-18.2W / 400mA, 3.6-20.8W / 450mA, 4.05-23.4W / 500mA, 4.5-26W 9-47.5Vdc, 60Vdc max, 550mA, 4.95-26.1W 9-43.5Vdc, 60Vdc max, 600mA, 5.4-26.1W 9-40Vdc, 60Vdc max, 650mA, 5.85-26W 9-37.5Vdc, 60Vdc max, 700mA, 6.3-26.3W ta: 50°C, tc: 85°C
Power Supply or Charger	LED Power Supply	EAGLERISE	FLS-44-1050 DALI-2 LD1	Input: LV supply: 220-240 Vac, 0/50/60 Hz, 0.34 A max., $\lambda$ : 0.65C-0.95 Centralized emergency power supply: 198-254 V= Output: 9-52Vdc, 60Vdc max, 700mA, 6.3-36.4W / 750mA, 6.75-39W / 800mA, 7.2-41.6W 9-49Vdc, 60Vdc max, 850mA, 7.65-41.7W / 900mA, 8.1-44.1W 9-46Vdc, 60Vdc max, 950mA, 8.55-43.7W 9-44Vdc, 60Vdc max, 1000mA, 9-44W 9-42Vdc, 60Vdc max, 1050mA, 9.45-44.1W ta: 50°C, tc: 90°C

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to [www.jas-anz.org/register](http://www.jas-anz.org/register) for verification.



Certification Manager





global-mark®

# Certificate of Conformity

Power Supply or Charger	LED Power Supply	EAGLERISE	FLS-42-1050 DALI-2 LD ADV	Input:LV supply:220-240 Vac,0/50/60 Hz,0.25 A max.,λ:0.25C-0.95 Centralized emergency power supply:198-254 V= Output: 2.5-52Vdc, 60Vdc max,150mA, 0.38-7.8W /200mA, 0.5-10.4W /250mA, 0.63-13W /300mA, 0.75-15.6W/350mA, 0.88-18.2W /400mA,1-20.8W /500mA,1.25-26W/600mA,1.5-31.2W/700mA, 1.75-36.4W /750mA,1.88-39W /800mA,2-41.6W 2.5-49Vdc, 60Vdc max, 850mA, 2.13-41.65W 2.5-46Vdc, 60Vdc max, 900mA, 2.25-41.4W 2.5-44Vdc, 60Vdc max, 950mA, 2.38-41.8W 2.5-42Vdc, 60Vdc max, 1000mA, 2.5-42W 2.5-40Vdc, 60Vdc max, 1050mA, 2.63-42W ta:45°C, tc:85°C
Power Supply or Charger	LED Power Supply	EAGLERISE	FLS-42-1050 LD ADV	Input:LV supply:220-240 Vac,0/50/60 Hz,0.3 A max.,λ:0.4C-0.95 Centralized emergency power supply:198-264 V= Output: 9-52Vdc, 63Vdc max,300mA, 2.7-15.6W /350mA, 3.15-18.2W /400mA, 3.6-20.8W /450mA, 4.05-23.4W/500mA, 4.5-26W /550mA,4.95-28.6W /600mA,5.4-31.2W/650mA, 5.85-33.8W/700mA, 6.3-36.4W /750mA,6.75-39W /800mA,7.2-41.6W 9-42Vdc, 63Vdc max, 850mA, 7.65-35.7W/900mA,8.1-37.8W /950mA,8.55-39.9W/1000mA,9-42W 9-40Vdc, 63Vdc max, 1050mA, 9.45-42W ta:45°C, tc:80°C

<b>RELEVANT TRADEMARK (S)</b>

<b>COMMENTS OR CONDITIONS ON THE CERTIFICATION</b>
- classified as do not cover

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to [www.jas-anz.org/register](http://www.jas-anz.org/register) for verification.



Certification Manager





global-mark®

End of document

# Certificate of Conformity



This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to [www.jas-anz.org/register](http://www.jas-anz.org/register) for verification.



Certification Manager

Global-Mark Pty Ltd, Copyright 2012 - 407, 32 Delhi Road, North Ryde NSW 2113, Australia



Global-Mark.com.au®

JAS-ANZ



WWW.JAS-ANZ.ORG/REGISTER