



# Certificate of Conformity

NO CER221863

## Product

LED Power Supply

## Model/Type Ref.

FLS-15-350 LD1 ADV, FLS-21-500 LD1 ADV,  
FLS-30-750 LD1 ADV, FLS-40-1050 LD1 ADV,  
FLS-8-500 DALI-2 LA ADV, FLS-12-700 DALI-2 LA ADV

## Manufacturer

EAGLERISE ELECTRIC & ELECTRONIC (JI AN) CO.,  
LTD  
West Zone, Ji An County Industrial Park, Ji an County  
Jiangxi Province  
China

**A sample of the product was tested  
and found to be in conformity with**

EN 61347-1:2015;A1  
EN 61347-2-13:2014;A1  
EN IEC 55015:2019;A11  
EN IEC 61000-3-2:2019;A1;A2  
EN 61000-3-3:2013;A1;A2  
EN IEC 61547:2023  
EN 62493:2015;A1

Additional information ref. the Appendix.

## Date of issue

2025-08-27

*Jiyea Gim*

Jiyea Gim

This certificate documents conformity of the product with the standards shown. It is a Scheme type 1a certificate according to ISO/IEC 17067. The certificate is valid for the certified type only. Any changes to the design of the certified type may imply that a re-certification is required. New standards or amendments to the standards may imply that the certification may need to be updated. This certificate does NOT give the manufacturer permission to use the Nemko mark.

## Appendix to Statement

**NO CER221863**

### Brand name / Trademark



### Ratings

PRI: max. 0.25 A, 220-240 V~, 0/50/60 Hz  
Centralized emergency power supply: 220-240 V DC  
SEC: max. 42 W, max. 1.05 A, 2.5-49 Vd.c. (under load), max. 60 Vd.c. (no-load),  
EOFI: 100% (For FLS-15-350 LD1 ADV, FLS-21-500 LD1 ADV, FLS-30-750 LD1 ADV and FLS-40-1050 LD1 ADV),  
EOFI: 85% (For FLS-8-500 DALI-2 LA ADV and FLS-12-700 DALI-2 LA ADV)

### Principal Characteristics

Independent type, Class II, SELV, constant current output, thermal protected 110 °C, ta: 45 °C, tc: 80 °C

### Additional Information

### Report reference

REP110324, REP110621