

CERTIFICATE

Issued to:
Applicant:
**EAGLERISE ELECTRIC & ELECTRONIC (JI AN)
CO., LTD**
West Zone, Ji An County Industrial Park
Ji An County Jiangxi, China

Licensee:
**Foshan Eaglerise Power Science & Technology
(Shunde) Co.,Ltd.**
No.4, East Huanzhen Road, Beijiao Shunde
528000 Foshan, Guangdong, China

Product : LED Power Supply
Trade name(s) : EAGLERISE
Type(s)/model(s) : LS-12-250 LI2 EXC, LS-12-300 LI2 EXC, LS-15-350 LI2 EXC,
LS-21-400 LI2 EXC, LS-21-450 LI2 EXC, LS-21-500 LI2 EXC,
LS-8-150 LI2 EXC, LS-8-180 LI2 EXC, LS-8-200 LI2 EXC and
LS-8-220 LI2 EXC

The product and any acceptable variation thereof as specified in the Annex to this certificate and the documents referred to therein.

DEKRA hereby declares that the above-mentioned product has been certified based on:

- a type test according to EN 61347-1:2015, EN 61347-1:2015/A1:2021, EN 61347-2-13:2014, EN 61347-2-13:2014/A1:2017 and EN IEC 62384:2020
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 2178893


DEKRA hereby grants the right to use the ENEC certification mark.

The ENEC certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the ENEC certification agreement.

This certificate is issued on 26 September 2025 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 35-165321

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



Kreny Lin
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: LED Power Supply
Trade name(s)	: EAGLERISE
Type(s)/model(s)	: LS-12-250 LI2 EXC, LS-12-300 LI2 EXC, LS-15-350 LI2 EXC, LS-21-400 LI2 EXC, LS-21-450 LI2 EXC, LS-21-500 LI2 EXC, LS-8-150 LI2 EXC, LS-8-180 LI2 EXC, LS-8-200 LI2 EXC and LS-8-220 LI2 EXC
Rated voltage	: 220-240 V~
Rated frequency	: 50/60 Hz
Power factor	: 0,95
Degree of protection	: IP20
Ambient temperature (ta)	: 45 °C
Additional information	: Class II, SELV, independent type, constant current output, non-inherently short-circuit proof, 110 °C thermal protection;

TESTS**Test requirements**

EN 61347-1:2015
EN 61347-1:2015/A1:2021
EN 61347-2-13:2014
EN 61347-2-13:2014/A1:2017
EN IEC 62384:2020

Test result

The test results are documented in DEKRA test file 4943194.50,4943194.51.

Additional information

The list of components is laid down in test report 4943194.50.

Conclusion

The examination has confirmed that all requirements were met.

Factory location

EAGLERISE ELECTRIC & ELECTRONIC (JI AN) CO., LTD
West Zone, Ji An County Industrial Park
Ji An County Jiangxi, China

Trade name : EAGLERISE stands for 

Detailed Model List:

Series	Model	Input				Output				ta (°C)	tc (°C)
		Voltage (VAC)	Max. Current (mA)	Frequency (Hz)	Power Factor	Constant Current (mA)	Normal Working Voltage (Vdc)	No Load Working Voltage (Vdc)	Max. Power (W)		
1	LS-8-150 LI2 EXC	220-240VAC	48	50/60Hz	0.95	150	27-42	59	6.3	45	75
	55		180			7.6					
	58		27-40			8					
	63					220	8.8				
	LS-12-250 LI2 EXC	220-240VAC	75	50/60Hz		250	27-42	59	10.5	45	75
	85		300			27-40	12				
	LS-15-350 LI2 EXC		100			50/60Hz	350		27-40		
2	LS-21-400 LI2 EXC	220-240VAC	120	50/60Hz	0.95	400	27-42	59	16.8	45	80
	130		450			18.9					
	LS-21-500 LI2 EXC		140			500			21		