ATTESTATION ◆ ATTESTATO ◆ ATTESTACIÓN ◆ BESCHEINIGUNG ◆ ATTESTATION

Attestation of Conformity

No. N8A 105345 0018 Rev. 00

Holder of Attestation: **Eaglerise Electric & Electronic (Ji'an) Co., Ltd.**
Southwest Corner of Panlong Road and Chaoyang Road
Ji'an Industrial Park
343100 Ji'an County, Jiangxi Province
PEOPLE'S REPUBLIC OF CHINA

Product: **Electronic controlgear for LED modules (Constant Current LED Power Supply)**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 211-902860-000

Date, 2026-09-28

(Taylor Yao)

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

TÜV SÜD Product Service GmbH • Ridlerstraße 65 • 80339 Munich • Germany

ATTESTATION ◆ ATTESTATO ◆ ATTESTACIÓN ◆ BESCHEINIGUNG ◆ ATTESTATION

Attestation of Conformity

No. N8A 105345 0018 Rev. 00

Model(s):

ITS FIX 20/220-240/350 N CS L;
ITS FIX 20/220-240/350 N CS L CCT;
ITS FIX 40/220-240/350 N CS L;
ITS FIX 40/220-240/350 N CS L CCT;
ITS FIX 65/220-240/350 N CS L;
ITS FIX 65/220-240/350 N CS L CCT;
ITS FIX 80/220-240/550 N CS L;
ITS FIX 80/220-240/550 N CS L CCT

Brand: **OSRAM**

Parameters:

Rated Input Voltage: 220-240VAC or 220-240VAC/DC
Rated Frequency: 50/60Hz or 0/50/60Hz
Rated Input Current: See below table for details
Rated Output: See below table for details
Protection Class: I (with endcap)
Protection against Electric Shock: Non-isolating
Degree of Protection: IP20 (with endcap); IP00 (without endcap)
Method of Installation: Independent (with endcap); Built-in (without endcap)
Type of Output: Constant current type
ta: -20...+60°C
tc: See below table for details

Tested according to:

EN IEC 61347-2-13:2024
EN IEC 61347-1:2024
EN 62493:2015/A1:2022

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

TÜV SÜD Product Service GmbH • Ridlerstraße 65 • 80339 Munich • Germany

ATTESTATION ◆ ATTESTATO ◆ ATESTACIÓN ◆ BESCHEINIGUNG ◆ ATTESTATION

Attestation of Conformity

No. N8A 105345 0018 Rev. 00

Series	Model No.	Rated Input Current (A)	P_{rated} (W)	Output Voltage (VDC)	I_{rated} (mA)	U_{out} (VDC)	tc (°C)
1	ITS FIX 20/220-240/350 N CS L; ITS FIX 20/220-240/350 N CS L CCT	0.15	20.0	25-100	200	250	80
			20.0	25-80	250		
			20.0	25-66.7	300		
			20.0	25-57	350		
1	ITS FIX 40/220-240/350 N CS L; ITS FIX 40/220-240/350 N CS L CCT	0.25	40.0	40-200	200	250	85
			40.0	40-160	250		
			40.0	40-133	300		
			42.0	40-120	350		
2	ITS FIX 65/220-240/350 N CS L; ITS FIX 65/220-240/350 N CS L CCT	0.38	40.0	70-200	200	250	85
			50.0	70-200	250		
			60.0	70-200	300		
			64.8	70-185	350		
3	ITS FIX 80/220-240/550 N CS L; ITS FIX 80/220-240/550 N CS L CCT	0.5	44.0	40-220	200	250	85
			55.0	40-220	250		
			66.0	40-220	300		
			77.0	40-220	350		
			80.0	40-200	400		
			79.7	40-177	450		
			80.0	40-160	500		
			79.8	40-145	550		

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

TÜV SÜD Product Service GmbH • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®